

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7271-1209:157 Page 1 of 1

**CATEGORY:** Ionization Smoke Detector

**LISTEE:** System Sensor, 3825 Ohio Ave., St. Charles IL 60174  
Contact: Andrej Nikolic (630) 377-6674

**DESIGN:** Model 1100, 1112/24, 1112/24B\* and 1151 ionization smoke detectors. Model 1100 is a 2-wire smoke detector, Model 1112/24 and 1112/24B are 4-wire smoke detectors. Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as ionization smoke detectors when used in conjunction with listee's separately listed electrically compatible fire alarm control units and bases.

\*Rev. 07-09-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 14, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager